

Purchasing Department

Ste. #310 – City Hall
1301 Bacharach Blvd.
Atlantic City, NJ 08401-4603
Phone (609) 347-5390
Fax (609) 347-5250



To: All Prospective Bidders

From: Mary P. Mooney, Purchasing Agent

Date: 10/28/2021

RE: **ADDENDA # 4 BID 21-60 ATLANTIC AVENUE ROAD DIET, PHASE 1
FEDERAL PROJECT #STBGP-1100(300) NJDOT JOB #5502329**

You are hereby notified in accordance with the paragraph entitled "Interpretation and Addenda" of the above captioned project that the following has been issued to clarify the meaning of the specifications and the conditions and specifications set forth in said addendum are to be considered as binding as if the same was set forth in the original contract documents.

ATTACH THIS ADDENDUM TO THE SPECIFICATIONS WHEN SUBMITTING BID.

1. The following questions were received, and answers provided within:

Q: Plan 3 (of 36) shows the following items as Plan Quantity with zero If & Where Directed quantity. Please advise what plan shows this installation.

- a) #17 Traffic Signal Cable 5/c
- b) #18 Traffic Signal Cable 10/c
- c) #31 Controller Turn-on
- d) #32 CTSS Controller Unit
- e) #33 Controller, CTSS turn-on

A: Traffic signal cables are for the adjustment of traffic signal heads (item 19) and existing wire which may need to be replaced on the same pole. Item 31 Controller Turn On is when the GPS Timeclocks are installed. The quantity has been revised to match the quantity of the GPS Timeclocks (17 Units). Items 32 CTSS Controller Unit and 33 Controller, CTSS Turn On have been eliminated and are listed as no items on the revised bid form.

Q: NJDOT Standard Spec CTSS Controller Unit requires connection to a designated Control Center. Please provide network drawings showing this connection.

A: This question is not applicable due to the answer provided above.

Q: Will the Adaptive Software integration be required for this CTSS Controller Unit?

A: This question is not applicable due to the answer provided above.

Q: Adaptive control requires Adaptive Image Detectors. If answer to #3 is yes, please advise if this intersection already has Adaptive Image Detectors.

A: This question is not applicable due to the answer provided above.

Q: Plans 20-23 (of 36) include notes depicting existing utility lights to be demo'd and new lighting to be installed where the existing lights are. Be aware these lights will be dark during the construction process.

A: This statement is acknowledged, and the contractor shall work with Atlantic City and Atlantic City Electric to minimize the downtime of lighting.

2. The HMA 12.5M64 Surface Course has been changed to HMA 12.5M76 Surface Course.

The following pages contain:

A. Revised Bid Form – Addendum 4

THIS ADDENDUM SHALL BE RETURNED WITH ALL BIDS

I acknowledge receipt of this Addendum:

Signature

Company